

Fire Protection Survey Services TM

6515 Rama Road, General Delivery
Longford Mills, Ontario, Canada, L0K 1L0
Telephone: (705) 326-0783 Fax: (208) 474-3520
Cell Phone: (705) 323-6248 E-mail: firepss@svmpatico.ca
Website: <http://hometown.aol.ca/firepss>

July 21, 2007

Township of Mapleton
Fire & Rescue Services
P. O. Box 1
Drayton, ON
N0G 1P0

Attention: Fire Chief Rick Richardson

Subject: Superior Tanker Shuttle Service Accreditation

Dear Chief Richardson:

Fire Protection Survey Services is pleased to award your municipality Superior Tanker Shuttle Service Accreditation. The test procedure was carried out on July 21, 2007 with the undersigned present. The flow rate during the 2-hour test period averaged 2,405 litres per minute or 530 imperial gallons per minute.

Your team worked in a well co-ordinated and organized manner with proper supervision.

Your municipality will require re-certification by August 01, 2012.

Regards,



Peter J. Rose, C.E.T., F.P.T.
Principal Partner
Senior Fire Protection Specialist